

TEST ATTESTATION

Contract no.: 1312/2019/1 - BF

21 January 2020
STG/PIK

Customer: Hermann Otto GmbH
Krankenhausstr. 14
DE-83413 Fridolfing

Subject: Test of the window connection system
"sprayable sealant with cords to connect to the construction component" according to the Austrian Standards ÖNORM B 5320 and ÖNORM B 5321

Result: With regard to the report 1312/19/1/O and the assessment 1312/2019/3, Holzforschung Austria hereby confirms that the window connection "**Sprayable sealant with cords to connect to the construction component**", consisting of

- OTTOSEAL® M 361 hybrid sealant,
- and/or OTTOSEAL® M 360 hybrid sealant,
- OTTO Primer 1225 adhesive primer and
- OTTOCORD PE-B2 cord


meets the requirements of the Austrian Standards ÖNORM B 5320, Section 4.8, and ÖNORM B 5321, Section 5.2.

Period of validity: --

HOLZFORSCHUNG AUSTRIA


DI Georg Steiner
Technical consultant




Dipl.-HTL-Ing. Peter Schober
Head of Department

In case of dispute the original German version prevails. This translation is for information purposes only.