



Hermann Otto GmbH
Postfach 20
83411 Fridolfing

Rotthauer Str. 19
45879 Gelsenkirchen

Phone (0209) 9242-230
Fax (0209) 9242-222
E-Mail c.schell@hyg.de
Internet www.hyg.de

Reference: W-150359e-07-SI
Responsible: Mrs. Dr. Ch. Schell

Gelsenkirchen, 02.07.2007

TEST CERTIFICATE

“OTTOSEAL® S 68” for use in cleanrooms

Determined by field testing, the suitability of “OTTOSEAL® S 68” for use in cleanrooms - from a hygienic-microbiological point of view - in accordance with test report W-150359-07-SI from 02.07.2007, can be confirmed.

This applies under the following conditions:

- the curing process of „OTTOSEAL® S 68” is completed
- OTTOSEAL® S 68 may not be in contact with water for days at a time (e.g. formation of condensation water)
- OTTOSEAL® S 68 has to be resistant to applied disinfectants
- OTTOSEAL® S 68 is used in accordance with regulations

From a hygienic-microbiological point of view and the current state of knowledge, “OTTOSEAL® S 68” is suitable for use in cleanrooms and ventilations ducts.

Gelsenkirchen, 02.07.2007

The Director of the Institute
on behalf

Dr. Ch. Schell
Department of Water Hygiene and Environmental Microbiology

